



Utility Information

ELECTRICAL:

A Georgia Power-owned substation on site provides a primary voltage of 13.8 kV.; secondary voltage is 4,160 volts. Internal transformers throughout the plant step down this voltage to various levels. The plant's location in the Ocmulgee East Industrial Park offers a number of service reliability and capacity advantages. Available substation capacities in place throughout the park exceed 30 MEW.

GAS:

Southern Natural Gas provides a 4-inch and 6-inch main redundant service to the plant.

WATER & SEWER:

The Macon Bibb County Water & Sewer Authority provides 6-inch and 8-inch water mains and 10-inch sewer main that serve the site.

Current capacity levels for the facility:

Sewer Capacity: In excess of 1.0 million gallons of sewer usage per day.

Water Capacity: In excess of 1.3 million gallons of water consumption per day.

****Note****

Additional capacity can be made available with the Macon Bibb County Water & Sewer Authority.